

# Henderson South Water Treatment Plant

## Finished Water

### Last 180 Days Report

03/25/19

to

09/20/19

	Min	Max	Avg	09/20/19	Units of Measure
Finished Water Turbidity	0.042	0.104	0.063	0.071	NTU
Finished Water Temperature	11.20	28.90	22.18	27.40	Deg. C
Finished Water pH	7.00	7.55	7.28	7.25	SU
Finished Water Alkalinity	67	142	99	122	mg/l
Finished Water Hardness	83	202	140	168	mg/l
Finished Water Conductivity	270	483	359	415	uS/cm
Finished Water Total Dissolved Solids	134.800	241.500	179.356	207.000	mg/l
Finished Water Fluoride	0.68	1.24	0.85	0.81	mg/l
Finished Water Iron	0.000	0.018	0.004	0.002	mg/l
Finished Water Manganese	0.000	0.023	0.009	0.013	mg/l
Finished Water Phosphate	0.060	0.620	0.285	0.390	mg/l

#### Grains of Hardness per Gallon

	Max	Average	09/20/19
Finished	11.813	8.161	9.825